



## Our Drinking Water Is Regulated

The City of The Colony is pleased to share this report with you. This report is a summary of the quality of the water we provide our customers. The analysis covers January 1 through December 31, 2018, and was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) and Texas Commission on Environmental Quality (TCEQ) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

## Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

## Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of The Colony Water Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in customer plumbing components. When your water has been sitting in the home piping for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## All Drinking Water May Contain Contaminants

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. In order to ensure that tap water is safe to drink, EPA prescribes

regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

## Where Do We Get Our Drinking Water?

The City of The Colony owns and operates five water wells that produce up to 9 Million Gallons per Day (MGD) of treated water. Four wells are on the Trinity Sands Aquifer and one well on the Paluxy Aquifer. The Colony purchases up to 6 MGD of treated surface water from Dallas Water Utilities (DWU). DWU water is supplied from seven reservoirs: Lake Lewisville, Lake Ray Roberts, Lake Ray Hubbard, Lake Tawakoni and Lake Fork.

The City purchases up to 4 MGD of treated water from the City of Plano. This is a small area of Austin Ranch in The Colony, which lies south of State Highway 121 and east of the MKT Railroad line to the eastern city limits. Plano's water is supplied by North Texas Water Utility District (NTMWD). NTMWD water is supplied from three reservoirs: Lake Lavon, Lake Jim Chapman and Lake Texoma.

The Colony owns and operates the water system within the city limits regardless of the supplier. The water quality within the system is monitored and tested in accordance to State and Federal laws by the city's staff of state licensed water system operators.

## Water Loss

In the water loss audit submitted to the Texas Water Development Board for the time period of January – December 2018, The Colony's system lost an estimated 9.93% of the system input volume. If you have any questions about the water loss audit, please call (972) 624-4431.

PWS ID #0610081

## Frequently Asked Questions

### What is this report and why do I receive it every year?

Water system providers are mandated by federal law to provide their customers with an annual consumer confidence report (annual water quality report). This report serves many functions. It allows you, the user, to make informed choices about your water; also, it allows you to know what contaminants, if any, are in your water, and allows your water provider a chance to tell you everything it takes to deliver safe drinking water to your tap.

### What causes my water to occasionally have a "milky" appearance?

A "milky" look is caused when tiny air bubbles are in the water. These form when the water coming into your home or business is under pressure and gasses (air) are dissolved and trapped in the pressurized water. These bubbles will not affect the quality or the taste of your water.

### Is it okay to use hot water from the tap for cooking and drinking?

You should always use cold water since hot water has a higher chance of containing potential contaminants from your household plumbing and water heaters. These contaminants can include, but are not limited to rust, copper, and lead and can dissolve in hot water faster than they can in cold water.



### How much water do I use during a typical shower?

Based on the age of your house and your shower heads, anywhere from 20 to 40 gallons of water can be used during a typical shower.

### What can I do to conserve water?

There are many things you can do to conserve water. Running your clothes washer and dishwasher only when they are full can save up to 1,000 gallons a month. Watering your lawn and garden in the morning or evening when temperatures are cooler will help minimize evaporation. Shortening your shower by a minute or two can save up to 150 gallons per month. Turning off the water while you are brushing your teeth can save up to 25 gallons per month. Also, take time to review your water bill on a regular basis as this can help you quickly realize if there are leaks in your system.



### Public Participation Opportunities

The public is invited to participate at the next meeting

**Date:** July 11th, 2019 **Time:** 5:30pm—6:00pm


**Location:** City Hall Annex Building, 6804 Main St., The Colony, TX 75056

**Phone:** (972) 624-4433

For more information about this report, or for any questions relating to your drinking water, please contact Robert Lassiter, Water Production, Water Quality Technician, at (972) 624-4436.

### En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. (972) 625-1756 — para hablar con una persona bilingüe en español.



PWS ID #0610081

## 2018 Testing Results

We routinely monitor for constituents in your drinking water according to Federal and State laws. The test results table shows the results of our monitoring for the period of January 1st to December 31st, 2018. In the table you might find terms and abbreviations you are not familiar with. To help you better understand these terms we've provided the following definitions:

### DEFINITIONS

**Action Level (AL)** – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Action Level Goal (ALG)** – the level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

**Avg.** – Regulatory compliance with some MCLs is based on running annual average of monthly samples.

**<** – Symbol indicates the level found is less than the number that follows it.

**Maximum Contaminant Level (MCL)** – the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – the level of a drinking water disinfectant below which there is no known expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**mrem** – millirems per year (a measure of radiation absorbed by the body).

**NA** – not applicable.

**ND** – not detected.

**NU** – not applicable. Nephelometric Turbidity Units.

**Parts per billion (ppb)** – micrograms per liter (µg/l) or one ounce in 7,800 gallons of water.

**Parts per million (ppm)** – milligrams per liter (mg/l) or one ounce in 7,800 gallons of water.

**TT** – Treatment Technique is a required process intended to reduce the level of a contamination in drinking water.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

| Regulated Substances                 |              |              |              |                 |                |                          |                |                        |                |                     |             |   |
|--------------------------------------|--------------|--------------|--------------|-----------------|----------------|--------------------------|----------------|------------------------|----------------|---------------------|-------------|---|
| Substance and unit of measure        | Colony       |              |              | MCLG [MRDLG]    |                | The Colony Water Utility |                | Dallas Water Utility   |                | Plano Water Utility |             | Typical Source  |
|                                      | Year Sampled | Year Sampled | Year Sampled | Amount Detected | Range Low-High | Amount Detected          | Range Low-High | Highest Level Detected | Range Low-High |                     |             |   |
| Atrazine (ppb)                       | NA           | 2018         | 2018         | 3               | 3              | NA                       | NA             | 0.17                   | .02–.10        | 0.3                 | .20–.30     | Runoff from herbicide on row crops  |
| Barium (ppm)                         | 2018         | 2018         | 2018         | 2               | 2              | 0.079                    | 0.079          | 0.027                  | 0.021–0.032    | 0.068               | 0.058–0.068 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| Beta/alpha emitters (pCi/L)          | NA           | NA           | 2018         | 0               | 50             | NA                       | NA             | NA                     | NA             | 8                   | 8.0–8.0     | Decay of natural and man-made deposits  |
| Bromate (ppb)                        | NA           | 2018         | NA           | 10^             | 0              | NA                       | NA             | 5                      | <1–12.0        | NA                  | NA          | By-product of drinking water ozonation  |
| Chromium (ppb)                       | NA           | 2018         | NA           | 100             | 100            | NA                       | NA             | 1                      | 1.0–1.0        | NA                  | NA          | Discharge from steel and pulp mills; erosion of natural deposits  |
| Cyanide (ppb)                        | 2017         | 2018         | NA           | 200             | 200            | 39.6                     | 30.3–49.1      | 14                     | 0–43           | NA                  | NA          | Waste from industrial chemical factories  |
| Fluoride (ppm)                       | 2018         | 2018         | 2018         | 4               | 4              | 0.488                    | 0.488          | 0.627                  | 0.520–0.765    | 0.264               | 0–0.0264    | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| Gross Alpha (pCi/L)                  | 2017         | NA           | NA           | 0               | 15             | 3.3                      | 3.3            | NA                     | NA             | NA                  | NA          | Decay of natural or man-made deposits   |
| Gross beta particle activity (pCi/L) | NA           | 2017         | NA           | 0               | 50             | NA                       | NA             | 5.1                    | 4.2–6.6        | NA                  | NA          | Decay of natural or man-made deposits   |
| Haloacetic Acids [HAA's] (ppb)       | 2018         | NA           | NA           | NA              | 60             | 14.5                     | 2.6–27.2       | NA                     | NA             | NA                  | NA          | By-product of drinking water disinfection   |
| Nitrate as N (ppm)                   | 2018         | NA           | NA           | NA              | NA             | 0.3082                   | 0.457–0.809    | NA                     | NA             | NA                  | NA          | Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits                               |
| Radium 228 (pCi/L)                   | 2017         | NA           | 2017         | 0               | 5              | 1.96                     | 1.96           | NA                     | NA             | 1.27                | 1.27–1.27   | Decay of natural or man-made deposits   |
| Simazine (ppb)                       | NA           | 2018         | 2018         | 4               | 4              | NA                       | NA             | 0.15                   | .11–.17        | 0.13                | 0–0.13      | Herbicide runoff  |
| Total Trihalomethanes [THMs] (ppb)   | 2018         | NA           | NA           | NA              | 80             | 20.5                     | 10.9–38.8      | NA                     | NA             | NA                  | NA          | By-product of drinking water disinfection   |

| Substance                     | Year Sampled |              |              | Treated Water Alkalinity | Highest Single measurements | Lowest Monthly % of Samples Meeting Limits | Highest Single measurements | Lowest Monthly % of Samples Meeting Limits | Highest Single measurements | Lowest Monthly % of Samples Meeting Limits | Typical Source                       |
|-------------------------------|--------------|--------------|--------------|--------------------------|-----------------------------|--|-----------------------------|--|-----------------------------|--|--------------------------------------|
|                               | Year Sampled | Year Sampled | Year Sampled |                          |                             |  |                             |  |                             |  |                                      |
| Total Organic Carbon (ppm)    | NA           | 2018         | 2018         | 35% removal/SUVA (<2)    | NA                          | NA   | Amount Detected             | Range of Levels Detected                   | Highest Level Detected      | Range of Levels Detected                   |                                      |
| Drinking Water (ppm) as CaCO3 | NA           | 2018         | 2018         | NA                       | NA                          | NA   | 3.21                        | 2.31–4.09                                  | 3                           | 1.85–3.00                                  | Naturally present in the environment |
| Source Water (ppm)            | NA           | NA           | 2018         | NA                       | NA                          | NA   | NA                          | NA   | 4.7                         | 3.68–4.70                                  | Naturally present in the environment |
| Removal Ratio (%) removed     | NA           | NA           | 2018         | NA                       | NA                          | NA   | NA                          | NA   | 54.4%                       | 26.5–54.4                                  | NA                                   |

| Substance         | Year Sampled |              |              | Turbidity Limits | Highest Single measurements | Lowest Monthly % of Samples Meeting Limits | Highest Single measurements | Lowest Monthly % of Samples Meeting Limits | Highest Single measurements | Lowest Monthly % of Samples Meeting Limits | Typical Source |
|-------------------|--------------|--------------|--------------|------------------|-----------------------------|--|-----------------------------|--|-----------------------------|--|----------------|
|                   | Year Sampled | Year Sampled | Year Sampled |                  |                             |  |                             |  |                             |  |                |
| Turbidity (NTU)** | NA           | 2018         | 2018         | 0.3 (TT)         | NA                          | NA   | 0.2                         | 100%                                       | 0.45                        | 99.1%                                      | Soil runoff    |

### Secondary unregulated Substances

| Substance                         | Year Sampled |  |      | Secondary MCL | Amount Detected | Range Low-High | Highest Level Detected | Range Low-High | Typical Source   |
|-----------------------------------|--------------|--|------|---------------|-----------------|----------------|------------------------|----------------|--|
| Calcium (ppm)                     | 2018         |  | 2018 | NA            | 3.31            | 3.31           | 55.3                   | 43.6–55.3      | Abundant naturally occurring element   |
| Chloride (ppm)                    | NA           |  | 2018 | NA            | NA              | NA             | 93.7                   | 30.8–93.7      | Abundant naturally occurring element; used in water purification; by-product of oil field activity |
| Magnesium (ppm)                   | 2018         |  | 2018 | NA            | 0.749           | 0.749          | 9.61                   | 9.18–9.61      | Abundant naturally occurring element   |
| Hardness, Calcium/Magnesium (ppm) | 2018         |  | NA   | NA            | 11.3            | 11.3           | NA                     | NA             | Naturally occurring soluble mineral salts  |
| pH (pH Units)                     | 2011         |  | 2018 | 6.5–8.5       | 8.6             | 8.5–8.7        | 8.51                   | 7.83–8.51      | Measure of corrosivity of water  |
| Sodium (ppm)                      | 2018         |  | 2018 | NA            | 324             | 324            | 88.6                   | 86.8–88.6      | Erosion of natural deposits; by-product of oil field activity                                      |
| Sulfate (ppm)                     | 2018         |  | 2018 | NA            | 83              | 83             | 134                    | 86–134         | Naturally occurring; common industrial by-product; by-product of oil field activity                |
| Total Hardness as CaCO3 (ppm)     | NA           |  | 2018 | NA            | NA              | NA             | 188                    | 105–188        | Naturally occurring calcium  |
| Total Dissolved Solids (ppm)      | NA           |  | 2018 | NA            | NA              | NA             | 556                    | 288–556        | Total dissolved mineral constituents in water  |
| Total Alkalinity (As CaCO3)       | 2018         |  | 2018 | NA            | 312             | 312            | 101                    | 65–101         | Naturally occurring soluble mineral salts  |

UCMR 4: Unregulated Contaminants Monitoring Rule 4  
Unregulated Contaminates are those of which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. Any unregulated contaminants detected in the following table. For additional information call the SAFE Drinking Water Hotline (800) 426-4791.

| Substance          | Year Sampled | MCLG [MRDLG] | MCL [MRDL] | Amount Detected | Range Low-High | Typical Source  |
|--------------------|--------------|--------------|------------|-----------------|----------------|---|
| Cylindrospermopsin | 2018         | N/A          | N/A        | ND              | ND             | Cyanobacteria which are found naturally in lake, stream, ponds, and other surface waters. |
| Anatoxin-a         | 2018         | N/A          | N/A        | ND              | ND             | Cyanobacteria which are found naturally in lake, stream, ponds, and other surface waters. |
| Total Microcystins | 2018         | N/A          | N/A        | ND              | ND             | Cyanobacteria which are found naturally in lake, stream, ponds, and other surface waters. |

### Maximum Residual Disinfectant Level

| The Colony Water Utility              |              |                                 |                                  |                                   |              |            |  |
|---------------------------------------|--------------|---------------------------------|----------------------------------|-----------------------------------|--------------|------------|--|
|                                       | Year Sampled | Average level of Quarterly Data | (Lowest result of single sample) | (Highest result of single sample) | MCLG [MRDLG] | MCL [MRDL] | Typical Source   |
| Chlorine Residual (Chloramines) (ppm) | 2018         | 2.88                            | 0.5                              | 4.6                               | [4]          | [4]        | In distribution system. Disinfectant is used to control microbes |

### Tap Water Samples: Lead and Copper

| The Colony Water Utility |              |                 |                       |                                 |      |              |  |
|--------------------------|--------------|-----------------|-----------------------|---------------------------------|------|--------------|--|
| Lead and Copper          | Year Sampled | 90th Percentile | Total Number of Sites | Number Sites above Action Level | MCLG | Action Level | Typical Source   |
| Copper (ppm)             | 2016         | 0.23            | 30                    | 0                               | 1.3  | 1.3          | Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems |
| Lead (ppm)               | 2016         | 0.0019          | 30                    | 0                               | 0    | 15           | Corrosion of household plumbing systems; erosion of natural deposit                                    |